



# thermo-electra

measurement and control technics



## Declaration of Conformity in accordance with European Directive 94/9/EC

Manufacturer: **Thermo-Electra B.V.**

Address: **Weteringweg 10, NL 2641KM Pijnacker**

Equipment Type: **LEX 25 Temperature sensors for zone 0, 1 or 2**



### Directive 94/9/EC ATEX

Provisions of the Directive fulfilled by the Equipment:

**Group II Category 1G EEx ia II T4...T6**

Notified Body for EC-Type Examination:

**KEMA QUALITY B.V. Arnhem, The Netherlands**

EC-type Examination Certificate:

**KEMA 02ATEX1238X**

Notified Body for production/identification number:

**KEMA QUALITY B.V. / 0344**

Utrechtseweg 310 6812 AR Arnhem, The Netherlands

Harmonised Standards used:

EN 60079-11:2007

EN 60079-0:2006

Other Standards and Specifications used:

EN 60079-0:2004 (Technically identical to EN 60079-0:2006 which is harmonised)

EN 50020:2002 (A review against EN 60079-11:2007, which is harmonised, shows no significant changes relevant to this equipment so EN 50020:2000 continues to represent "State of the Art".

EN 50284:1999 (A review against EN 60079-26:2007, which is harmonised, shows no significant changes relevant to this equipment so EN 50284:1999 continues to represent "State of the Art".

On behalf of the above named company, I declare that, on the date the equipment accompanied by this declaration is placed on the market, the equipment conforms with all technical and regulatory requirements of the above listed directives.

Pijnacker, 02.02.2010

F.A.Th. van Leeuwen

Managing director